

Product Change Notification

Product: FU210 / IV210 / PV210 / ZU210 – Signal Converter

Date: 15.09.2020

Description of change / innovation: USB interface implemented

| FU210 / IV210 / PV210 / ZU210 (old version) | FU210 / IV210 / PV210 / ZU210 (new version) |
|--|--|
|  |  |
| Valid manual: ZU210_03b | Valid manual: ZU210_04a |
| Valid firmware: ZU21003x | Valid firmware: ZU2104a |
| No USB interface | <p>4.9. USB interface (X7) A serial USB interface (mini USB) is available at terminal X7.</p> <p>The USB interface can be used as follows:</p> <ul style="list-style-type: none"> • For parameterization of the device during commissioning • To change parameters during operation • For reading out actual values via PC <div style="border: 1px solid black; padding: 5px; margin-top: 10px;">  <p>The serial USB communication is done with a baud rate of "115200 Baud" and a serial data format of "8none1" and cannot be changed by the user!</p> </div> |
| | |