



Member of the FM Global Group

FM Approvals
1151 Boston Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781-762-9375 www.fmapprovals.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS LOCATION ELECTRICAL EQUIPMENT PER CANADIAN REQUIREMENTS

This certificate is issued for the following equipment:

18abcde-f-g Shaft Rotation Speed Sensors

IS/I,II,III/1/ABCDEFG/T5 Ta* -- 990-006100 Entity; Type 4X, IP65
I/O/Ex ia IIC/T5 Ta* -- 990-006100 Entity; Type 4X, IP65

Entity Parameters:

U_i = 30V, I_i = 100mA, P_i = 0.7W, C_i = 0.042uF, L_i = 0uH.

a = Housing: B, E, R or F.

b = Sensor type: H or M.

c = Signal: S or Q.

d = Output: N or P.

e = Termination: O or T.

f = Cable length in feet: Any three digits 001 to 100 or Blank.

g = Wide temperature option: W or Blank.

Housing Option (a)	Wide Temperature Option (g)	T code	*Ambient Range (Ta)
E	Blank	T5	-30°C < Ta < 80°C
B, R, F	Blank	T5	-20°C < Ta < 80°C
B, R, F	W	T5	-40°C < Ta < 85°C

Equipment Ratings:

Intrinsically safe for Class I/II/III, Division 1, Groups A, B, C, D, E, F, and G;

Intrinsically safe for Class I, Zone 0, Group IIC;

Hazardous Locations, indoor and outdoor Type 4X, IP65.

FM Approved for:

Electro-Sensors Inc
Minnetonka, MN United States



Member of the FM Global Group

This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

CAN CSA-C22.2 No. 157-92	1992 (2012)
CAN CSA-C22.2 No. 1010-1	2004 (2009)
CAN CSA-C22.2 No. 25	1966 (2009)
CAN CSA-C22.2 No. 60529-05	2005 (2010)
CAN CSA-C22.2 No. E60079-0	2011
CAN CSA-C22.2 No. E60079-11	2011

Original Project ID: 3050257C

Approval Granted: July 17, 2014

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
---------------	------	---------------	------

FM Approvals LLC

J.E. Marquedant
Manager, Electrical Systems

17 July 2014

Date

To verify the availability of the Approved product, please refer to www.approvalguide.com